



Monitoring Data for the Goulburn Water Treatment Plant 2020

233-235 Wheeo Road Goulburn

Licence 1649

Location - Overflow pipe from Settling Dam on River Street

Date Published:

Condition M2 - Required Monthly Monitoring

Condition M6 - Volume Discharged

Date	Biochemical Oxygen Demand (mg/L)	Suspended Solids (mg/L)
8/01/2020	<2	7
5/02/2020	<2	19
4/03/2020	3	12
1/04/2020	<2	12
6/05/2020	<2	7
5/06/2020	<2	11
1/07/2020	<2	6
7/08/2020	<2	8
9/09/2020	<2	7
14/10/2020	<2	3
11/11/2020	<2	10
2/12/2020	<2	10

Limit	20	50
Average	3.0	9.3
Maximum	3	19
Minimum	3	3

	January	February	March	April	May	June	July	August	September	October	November	December
1	200	200	50	200	75	200	25	200	50	75	50	200
2	150	175	175	100	150	0	125	0	125	150	100	0
3	175	50	100	50	200	125	175	100	175	200	150	50
4	75	25	75	50	0	175	0	150	0	50	200	125
5	150	0	200	0	0	200	75	200	75	150	50	200
6	200	200	100	200	0	0	150	50	125	200	125	50
7	200	125	25	125	0	50	200	125	200	0	200	100
8	150	175	150	50	125	100	0	175	0	75	0	150
9	125	200	75	175	175	175	75	0	50	125	75	200
10	200	0	0	100	200	0	150	75	125	200	125	0
11	0	50	0	20	0	75	200	125	200	50	200	75
12	175	200	200	150	75	150	0	200	50	100	50	125
13	125	125	125	125	125	200	100	50	125	100	150	200
14	200	175	50	50	200	50	175	100	175	200	200	50
15	0	50	175	175	0	150	50	200	0	0	50	100
16	125	200	125	200	100	200	125	0	75	125	125	150
17	125	50	175	75	150	0	200	75	125	150	200	200
18	200	200	0	20	200	75	0	150	175	50	0	0
19	50	150	0	175	25	125	75	200	0	125	50	100
20	150	125	200	120	150	200	125	0	100	175	100	150
21	150	175	75	50	200	50	200	75	150	0	175	200
22	175	200	150	50	0	100	50	125	200	75	0	0
23	125	0	125	200	75	200	150	200	50	125	100	125
24	200	125	50	125	125	0	200	0	125	200	200	175
25	125	200	0	50	150	75	0	75	200	50	50	200
26	50	125	175	175	50	125	75	125	0	100	125	50
27	200	75	75	200	175	200	125	200	100	200	175	100
28	175	200	50	50	200	25	200	50	150	0	0	175
29	125	200	25	175	25	100	25	100	200	75	100	200
30	50	0	0	100	100	175	100	175	0	150	150	75
31	200		150		175		150	0		200		