



## Monitoring Data for the Goulburn Water Treatment Plant

233-235 Wheeo Road Goulburn

Licence 1649

Location - Overflow pipe from Settling Dam on River Street

Date Published:

Condition M2 - Required Monthly Monitoring

Condition M6 - Volume Discharged

Date	Biochemical Oxygen Demand (mg/L)	Suspended Solids (mg/L)
6/01/2021	<2	10
10/02/2021	<2	5
3/03/2021	<2	4
7/04/2021	<2	10
6/05/2021	<2	10
3/06/2021	<2	5
7/07/2021	<2	5
4/08/2021	<2	16
8/09/2021	<2	8
6/10/2021	2	42
6/11/2021	<2	10
8/12/2021	<2	27

Limit	20	50
Average	2.0	12.7
Maximum	2	42
Minimum	2	4

	January	February	March	April	May	June	July	August	September	October	November	December
1	200	25	200	150	50	175	200	175	0	50	50	50
2	50	175	100	175	200	75	200	50	50	175	175	100
3	125	125	50	200	150	200	175	150	100	200	50	200
4	200	50	50	150	175	125	150	200	150	175	125	0
5	0	25	0	175	75	200	200	0	200	100	200	75
6	75	0	200	175	150	150	50	150	0	200	0	150
7	100	200	125	100	200	75	175	50	125	150	75	200
8	175	100	50	150	200	50	200	125	200	200	150	50
9	50	50	175	200	150	200	175	200	0	200	200	100
10	100	50	100	200	125	125	150	0	50	175	0	175
11	175	175	20	175	200	200	100	75	125	100	100	50
12	200	75	150	150	0	75	75	150	200	200	150	150
13	0	75	125	175	175	125	100	200	0	75	200	200
14	125	150	50	100	125	125	175	0	75	200	0	0
15	200	75	175	200	200	125	200	100	125	175	75	75
16	50	75	125	200	0	75	175	150	200	200	150	150
17	100	175	75	175	125	200	150	200	0	150	200	200
18	175	75	20	200	125	50	75	0	50	150	50	50
19	50	50	175	175	200	200	75	75	100	200	125	75
20	125	50	200	150	50	175	175	150	175	150	175	100
21	150	25	50	200	150	125	200	50	0	175	50	200
22	200	175	50	0	150	200	175	125	50	200	100	0
23	0	75	200	125	175	175	150	200	125	150	150	75
24	100	50	125	200	0	125	100	0	200	150	50	125
25	200	25	50	75	200	175	175	100	0	200	150	200
26	50	175	175	100	75	175	75	175	50	200	200	0
27	125	100	150	150	200	125	175	200	75	175	0	75
28	200	50	50	200	125	200	200	0	150	150	75	150
29	50		175	150	175	125	175	75	200	200	150	200
30	75		100	200	75	125	200	100	0	175	200	50
31	150		0		0		150	175		200		125