



Monitoring Data for the Goulburn Water Treatment Plant

233-235 Wheeo Road Goulburn

Licence 1649

Location - Overflow pipe from Settling Dam on River Street

Date Published:

Condition M2 - Required Monthly Monitoring

Date	Biochemical Oxygen Demand (mg/L)	Suspended Solids (mg/L)
12/01/2022	<2	13
9/02/2022	<2	17
9/03/2022	<2	23
6/04/2022	4	8
4/05/2022	<2	8
1/06/2022	<2	8
20/07/2022	<2	6
3/08/2022	<2	17
1/09/2022	<2	5
7/10/2022	<2	6
8/11/2022	<2	21
7/12/2022	<2	4

Limit	20	50
Average	4.0	11.3
Maximum	4	23
Minimum	4	4

Condition M6 - Volume Discharged

	January	February	March	April	May	June	July	August	September	October	November	December
1	200	175	125	50	200	100	0	75	175	50	50	175
2	0	125	175	175	0	100	50	75	150	150	100	200
3	75	200	0	50	75	175	150	200	200	200	150	175
4	125	50	75	125	150	150	200	150	50	0	200	100
5	150	100	150	200	200	75	50	200	175	150	0	200
6	50	150	200	0	50	200	125	150	200	50	125	150
7	200	150	0	75	125	175	175	175	175	125	200	200
8	200	200	100	100	200	175	0	75	150	200	0	200
9	125	50	200	200	0	125	75	100	100	0	50	175
10	200	150	175	0	75	200	150	150	75	75	125	100
11	175	175	100	75	125	50	200	175	100	150	200	200
12	150	100	200	150	150	100	0	200	175	200	0	75
13	150	125	75	200	50	150	100	75	200	0	75	200
14	200	200	200	50	200	150	200	75	175	100	125	175
15	0	175	175	100	200	200	50	200	150	150	200	200
16	100	175	200	175	125	50	125	175	75	200	0	150
17	175	100	150	50	200	150	175	150	75	0	50	125
18	175	50	150	150	175	175	50	175	175	75	100	200
19	200	75	200	200	150	100	100	175	200	150	175	0
20	150	200	150	0	150	125	150	150	175	50	0	50
21	150	175	175	75	200	200	200	75	150	125	50	100
22	100	150	200	150	0	175	0	200	100	200	125	175
23	50	200	150	200	100	175	75	150	175	0	200	0
24	200	0	150	50	175	100	125	100	75	100	0	50
25	100	50	200	75	175	50	200	100	175	175	50	125
26	100	150	200	100	200	75	50	200	200	200	75	200
27	175	200	175	200	150	200	150	150	175	0	150	0
28	150	50	150	0	150	175	200	150	200	75	200	50
29	75		200	75	100	150	175	75	150	100	0	75
30	200		175	125	50	200	50	200	175	175	50	150
31	175		200		200		150	200		0		200