

Monitoring Data for the Goulburn Wastewater Treatment System
 License 1742 Condition M2 – Required Monitoring
 Monthly Monitoring



Point 26

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
7/05/2014	8.02	1040	5	21.2	5.04	4	352
12/06/2014	7.93	1140	3	21.2	4.42	3	<1
9/07/2014	8.07	1190	6	24.8	3.76	3	8
6/08/2014	8.26	1220	8	24.5	3.28	6	2
3/09/2014	7.81	1160	8	25.3	3.19	4	4
1/10/2014	8.04	1150	5	25.5	3.14	3	<1
5/11/2014	8.7	1110	16	23.5	3.84	7	9
3/12/2014	8.2	1120	10	14.9	4.17	10	90
8/01/2015	9.05	983	7	8.24	3.57	3	12
4/02/2015	9.65	866	25	8.34	2.24	5	74
4/03/2015	9.92	861	14	3.4	1.23	3	<2
8/04/2015	8.39	919	9	6.36	2.99	3	0
7/05/2015	8.05	999	7	13	5.03	4	740
3/06/2015	8.35	1010	9	15.4	4.83	6	0
1/07/2015	8.14	1060	10	19.9	4.33	6	0
5/08/2015	7.86	1010	6	17.4	3.69	7	0
2/09/2015	8	1010	10	20	3.23	7	36
7/10/2015	8.54	1000	12	17.9	4.16	7	2
4/11/2015	8.01	1040	3	17.4	5.53	4	2
2/12/2015	8.44	1060	7	14.5	5.93	2	0

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
7/01/2016	8.76	1050	9	9.37	5.09	5	75
5/02/2016	8.98	981	13	7.76	4.18	4	146
2/03/2016	8.88	1030	25	9.22	4.28	9	1750
6/04/2016	9.53	1010	55	7.34	2.65	4	4
4/05/2016	8.47	1070	31	10.1	4.24	10	8
1/06/2016	8.12	1170	11	18	3.69	7	710
6/07/2016	7.93	962	6	17.9	2.46	0	83
3/08/2016	7.96	971	5	20.1	2.13	0	0
7/09/2016	8.07	940	8	21.3	2.11	4	7
5/10/2016	8.02	944	10	20.8	2.5	2	48
2/11/2016	8.56	883	15	17.8	3.16	8	6
8/12/2016	8.94	849	10	10.5	3.61	4	0
4/01/2017	9.25	848	24	7.81	3.16	3	83
1/02/2017	9.91	875	48	6.23	1.46	6	0
1/03/2017	9.19	922	92	13.2	3.16	15	4560
5/04/2017	8.66	939	22	10.1	5.12	6	0
3/05/2017	8.07	1020	57	18.7	7.98	7	2
7/06/2017	8.1	1190	14	28.2	7.57	6	68
5/07/2017	8.02	1230	6	28.9	7.08	3	0
9/08/2017	8.14	1270	2	29.3	6.17	0	2
15/09/2017	8.23	1270	14	29.2	4.85	6	52
4/10/2017	8.35	1230	8	26.3	4.9	8	0
8/11/2017	8.5	1260	13	23.5	6.5	12	2
6/12/2017	8.23	1170	11	20.5	7	6	50
10/01/2018	8.71	1110	6	14.4	6.96	4	2
7/02/2018	9.02	1100	11	10.9	4.45	5	2

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
7/01/2016	8.76	1050	9	9.37	5.09	5	75
5/02/2016	8.98	981	13	7.76	4.18	4	146
2/03/2016	8.88	1030	25	9.22	4.28	9	1750
6/04/2016	9.53	1010	55	7.34	2.65	4	4
4/05/2016	8.47	1070	31	10.1	4.24	10	8
1/06/2016	8.12	1170	11	18	3.69	7	710
6/07/2016	7.93	962	6	17.9	2.46	0	83
3/08/2016	7.96	971	5	20.1	2.13	0	0
7/09/2016	8.07	940	8	21.3	2.11	4	7
5/10/2016	8.02	944	10	20.8	2.5	2	48
2/11/2016	8.56	883	15	17.8	3.16	8	6
8/12/2016	8.94	849	10	10.5	3.61	4	0
4/01/2017	9.25	848	24	7.81	3.16	3	83
1/02/2017	9.91	875	48	6.23	1.46	6	0
1/03/2017	9.19	922	92	13.2	3.16	15	4560
5/04/2017	8.66	939	22	10.1	5.12	6	0
3/05/2017	8.07	1020	57	18.7	7.98	7	2
7/06/2017	8.1	1190	14	28.2	7.57	6	68
5/07/2017	8.02	1230	6	28.9	7.08	3	0
9/08/2017	8.14	1270	2	29.3	6.17	0	2
15/09/2017	8.23	1270	14	29.2	4.85	6	52
4/10/2017	8.35	1230	8	26.3	4.9	8	0
8/11/2017	8.5	1260	13	23.5	6.5	12	2
6/12/2017	8.23	1170	11	20.5	7	6	50
10/01/2018	8.71	1110	6	14.4	6.96	4	2
7/02/2018	9.02	1100	11	10.9	4.45	5	2

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
7/03/2018	8.42	1020	12	9.02	5.38	8	1360
4/04/2018	8.17	1030	10	16.1	6.98	8	16900
3/05/2018	8.48	1050	6	13.9	7.38	4	8
6/06/2018	8.22	1110	14	7.73	5.79	7	3960
4/07/2018	8.06	1140	10	23.8	4.79	5	110
3/08/2018	7.91	1130	4	25.2	4.14	<2	<2
5/09/2018	8.08	1140	8	27.6	5.21	5	<2
3/10/2018	8.11	1210	4	30.5	6.61	4	<2
7/11/2018	8.18	1170	18	29.3	7.95	7	84
5/12/2018	8.27	1130	15	20.5	6.83	10	4
9/01/2019	8.36	1150	13	11.7	6.92	7	<2
6/02/2019	8.05	1090	4	5.84	15.8	<1	<1
6/03/2019	8.21	1060	<2	3.26	5.47	2	1
4/04/2019	8.19	1040	6	5.21	4.86	<2	6
1/05/2019	8.13	1070	2	4.33	5.03	<2	<2
5/06/2019	8.1	1010	6	4.32	3.74	3	40
3/07/2019	8.13	1000	3	3.73	2.6	3	<1
7/08/2019	7.85	1020	3	3.85	1.81	<2	<2
2/10/2019	8.83	1030	8	3.00	2.17	6	<2
12/11/2019	8.74	1050	5	2.38	4.31	3	<2
10/12/2019	8.53	1050	5	2.41	4.84	2	<2