



NOTES:

- CONTRACTOR TO PROVIDE STRUCTURAL ENGINEERS CERTIFICATION THAT ALL BALUSTRADES HAVE BEEN INSTALLED TO COMPLY WITH THE STRUCTURAL LOADING REQUIREMENTS OF AS1170.1
- REFER TO STRUCTURAL ENGINEERS DETAILS AND DOCUMENTATION FOR PROPPING REQUIREMENTS
- ALL STEEL WORK TO BE HOT DIP GALVANISED. SITE REPAIR ALL WELDS WITH COLD GALVANISED PAINT
- ALL STEEL FABRICATION TO BE DONE IN WORKSHOP AND TRANSPORTED ONTO SITE FOR INSTALLATION
- FORM 12mm EJ TO EACH BRICK SKIN WITH 50mm ABELFLEX STRIP. FILL JOINT WITH POLYETHYLENE FOAM BACKING ROD AND SEAL WITH COLOURED MASTIC. PROVIDE EJ AT MAX. 6m CENTRES UNLESS OTHERWISE SPECIFIED.
- PROVIDE SLIP JOINT BETWEEN CONCRETE SLAB AND SUPPORTING MASONRY WALLS.
- ALL SUBGRADE & COMPACTED FILL BELOW SLAB TO APPROVAL USING APPROVED GRANULAR MATERIAL COMPACTED TO 98% OF STANDARD DRY DENSITY.
- ALL FOOTINGS DOWN TO SOLID FORMATIONS WITH MIN. 150KPa. OR AS APPROVED BY SITE INSPECTION PRIOR TO CONCRETE POUR.


1 RAMP DETAIL PLAN
1:100 @ A1 SHEET SIZE



2 RAMP DETAIL SECTION
NOT TO SCALE



3 RAMP DETAIL SECTION
NOT TO SCALE



4 RAMP DETAIL SECTION
NOT TO SCALE



DRAWING AMENDMENTS		PROJECT FILE		DRAWING TITLE		DRAWING NUMBER		DRAWING DATE		DRAWING SHEET NO.	
AMENDMENT NO. A		NEW MEDICAL CENTRE		RAMP DETAIL		MAR 2024		-		TL	
ISSUED FOR DEVELOPMENT APPLICATION		CLIENT		LOT AND EROSION PLAN NO.		DRAWING SCALE		JOB NUMBER		AMENDMENT NO.	
		CARTWRIGHT VERNER PTY LTD		LOT 1 & 3 DP 1060354		S.A.S.		0224 - 1651		A	
		DATE: 05/24		SHEET NUMBER		AT SHEET		DRAWING IDENTIFICATION NUMBER		0224 - 1651 - 04	
		PROJECT ADDRESS		DRAWING AUTHOR		DRAWING CHECKER		DRAWING APPROVER			
		VERNER STREET		M. 0429098698		P. 02 48229934		T. 02 48229934			
		GOULBURN NSW 2580		NOMINATED ARCHITECT		TIM LEE (ARB 7304)					
		GOULBURN NSW 2580		DRAWING DATE		0224 - 1651 - 04					